

# Attestation

## LEED v4, v4.1 BETA, and v5

On 17<sup>th</sup> of March 2025, Eurofins Product Testing A/S received a sample of a joint sealant with the product name:

**HIT-HY 170**

supplied by

**Hilti Entwicklungsgesellschaft mbH**

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant CDPH 01350 and ASTM D2369 testing standards (See test report no. 392-2025-00144601\_H\_EN and no. 392-2025-20144603\_XG\_EN).

**The test results of the tested sample indicate that the product qualifies for LEED v4, LEED v4.1 BETA (February 2024), and LEED v5 (April 2025) projects globally by showing compliance with the specifications for VOC emissions and VOC content by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects globally:**

- The requirements of LEED v4, LEED v4.1 BETA (February 2024) and LEED v5 (April 2025) by: CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017); and a TVOC below 0.5 mg/m<sup>3</sup> in the classroom scenario and between 0.5 – 5 mg/m<sup>3</sup> in the office scenario.

**VOC content specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects globally:**

- The requirements of LEED v4 and LEED v4.1 BETA (February 2024): South Coast Air Quality Management District (SCAQMD) Rule 1168 (2022) for 'Multi-Purpose Construction Adhesive' having a VOC content below 70 g/L.

17 July 2025



Rasmus Verdier  
Analytical Service Manager

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*